

# Valentino

## توری فایبر گلاس Valentino AR 160

### ALKALI-RESISTANT FIBERGLASS MESH

گزارش کار آزمایشگاه تست توری مقاوم به قلیا

No.	Item	Standard	Standard	Test Result	Result
1	Appearance	JC/T 841-2007 5.7	The number of major defects per 100 square meters of the sample shall not exceed 10, and there shall no unacceptable defects	Rech standard	PASS
2	Wide	GB/T 7689.3-2013	1000±1.5 MM	1000	PASS
3	Density(/25mm)	GB/T 7689.3-2013	5	5	PASS
	Weft		5	5	
4	Weight per square meter (g/m <sup>2</sup> )	GB/T 9914.3-2013	160±8	161.3	PASS
5	Combustible content %	GB/T 9914.2-2013	≥2	≥13.9	PASS
6	Tensile Strength N/50mm	GB/T 9915.2-2013	≥1200	1728	PASS
			≥1200	2242	
7	Elongation at break	GB/T 9915.2-2013	≤4.0	3.83	PASS
			≤4.0	3.71	
8	Alkali Resistance	Warp		1494	PASS
				2099	
		Weft	≥75	86.5	PASS
			≥75	93.7	
9	ZrO <sub>2</sub> %	JC/T 41-2007 5.1	≥16.0	16.52	PASS